


华亚东营塑胶有限公司

产品检验报告/质量合格证

编号：HYDY/JLA-C05/015072904AD-A

第 1 页 / 共 1 页

委托单位	华亚东营塑胶有限公司生产一课	品牌	南亚牌	标志																																																																					
样品名称	PVC-U 给水管	规格型号	160mm×4.0mm																																																																						
样品编号	015072904AD-A	样品状态	颜色为灰色、外表光滑、截面平整无缺陷，数量满足试验要求																																																																						
生产日期	2015.07.27~2015.07.29	收样日期	2015.07.29																																																																						
检验日期	2015.07.30~2015.08.01	检验依据	GB/T 10002.1-2006																																																																						
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 25%;">检验项目</th> <th style="width: 25%;">技术指标</th> <th style="width: 25%;">检验结果</th> <th style="width: 25%;">单项判定</th> </tr> </thead> <tbody> <tr> <td>外观</td> <td>无缺陷</td> <td>无缺陷</td> <td>合格</td> </tr> <tr> <td>颜色</td> <td>灰色</td> <td>灰色</td> <td>合格</td> </tr> <tr> <td>平均外径mm</td> <td>160.0~160.5</td> <td>160.3</td> <td>合格</td> </tr> <tr> <td>壁厚mm</td> <td>4.0~4.6</td> <td>4.1</td> <td>合格</td> </tr> <tr> <td>不圆度mm</td> <td>≤3.2</td> <td>0.3</td> <td>合格</td> </tr> <tr> <td>弯曲度%</td> <td>≤1.0</td> <td>0.1</td> <td>合格</td> </tr> <tr> <td>长度 mm</td> <td>≥6000</td> <td>6020</td> <td>合格</td> </tr> <tr> <td>承口中部内径 mm</td> <td>160.2~160.5</td> <td>160.4</td> <td>合格</td> </tr> <tr> <td>承口最小深度 mm</td> <td>≥86.0</td> <td>165.0</td> <td>合格</td> </tr> <tr> <td>承口壁厚 mm</td> <td>≥3.0</td> <td>3.5</td> <td>合格</td> </tr> <tr> <td>水压试验 (20℃、诱导应力 38MPa)</td> <td>持压 1h 无破裂、无渗漏</td> <td>2.00MPa 持压 1h 无破裂、无渗漏</td> <td>合格</td> </tr> <tr> <td>落锤冲击试验 (0±2℃) TIR %</td> <td>≤5</td> <td>冲击 50 次均无破裂</td> <td>合格</td> </tr> <tr> <td>纵向回缩率 %</td> <td>≤5</td> <td>1.3</td> <td>合格</td> </tr> <tr> <td>倒角</td> <td>15° / 厚度≥2.0mm</td> <td>15° / 2.0</td> <td>合格</td> </tr> <tr> <td>不透光性</td> <td>不透光</td> <td>不透光</td> <td>合格</td> </tr> <tr> <td style="text-align: center;">总判定</td> <td colspan="3" style="text-align: center;">  </td> </tr> </tbody> </table>						检验项目	技术指标	检验结果	单项判定	外观	无缺陷	无缺陷	合格	颜色	灰色	灰色	合格	平均外径mm	160.0~160.5	160.3	合格	壁厚mm	4.0~4.6	4.1	合格	不圆度mm	≤3.2	0.3	合格	弯曲度%	≤1.0	0.1	合格	长度 mm	≥6000	6020	合格	承口中部内径 mm	160.2~160.5	160.4	合格	承口最小深度 mm	≥86.0	165.0	合格	承口壁厚 mm	≥3.0	3.5	合格	水压试验 (20℃、诱导应力 38MPa)	持压 1h 无破裂、无渗漏	2.00MPa 持压 1h 无破裂、无渗漏	合格	落锤冲击试验 (0±2℃) TIR %	≤5	冲击 50 次均无破裂	合格	纵向回缩率 %	≤5	1.3	合格	倒角	15° / 厚度≥2.0mm	15° / 2.0	合格	不透光性	不透光	不透光	合格	总判定			
检验项目	技术指标	检验结果	单项判定																																																																						
外观	无缺陷	无缺陷	合格																																																																						
颜色	灰色	灰色	合格																																																																						
平均外径mm	160.0~160.5	160.3	合格																																																																						
壁厚mm	4.0~4.6	4.1	合格																																																																						
不圆度mm	≤3.2	0.3	合格																																																																						
弯曲度%	≤1.0	0.1	合格																																																																						
长度 mm	≥6000	6020	合格																																																																						
承口中部内径 mm	160.2~160.5	160.4	合格																																																																						
承口最小深度 mm	≥86.0	165.0	合格																																																																						
承口壁厚 mm	≥3.0	3.5	合格																																																																						
水压试验 (20℃、诱导应力 38MPa)	持压 1h 无破裂、无渗漏	2.00MPa 持压 1h 无破裂、无渗漏	合格																																																																						
落锤冲击试验 (0±2℃) TIR %	≤5	冲击 50 次均无破裂	合格																																																																						
纵向回缩率 %	≤5	1.3	合格																																																																						
倒角	15° / 厚度≥2.0mm	15° / 2.0	合格																																																																						
不透光性	不透光	不透光	合格																																																																						
总判定																																																																									

批准： 

审核： 

编制： 检验员01

地址：山东省东营市东二路 251 号
 电话：0546-8305238
 邮政编码：257091

传真：0546-8307178
 E-mail: huaya@hydyplst.com.cn
 http://www.hydyplst.com.cn